

BID FORM & SPECIFICATIONS – EVT0001780

Ellsworth Correctional Facility

This Bid Event is for the replacement of existing walk-in freezer and refrigeration systems at Ellsworth Correctional Facility (ECF). There are four (4) medium temperature systems and three (3) low temperature systems. Bidders shall provide their pricing as required below. Site visits are scheduled through Bud Hachmeister, 1607 State St., Ellsworth, KS., 67439, 785-472-5501 ext. 46313.

Medium Temperature Systems

- 4 EA. 230 Volt, 3 Phase Medium Temperature Condensing Unit (1 - HP)
- 4 EA. 115 Volt, Evaporator
- 4 EA. SPO 3/8" X 1/2" OD TEV Valve SBFSE-A-C (expansion valve)

Low Temperature Systems

- 3 EA. 230 Volt, 3 Phase Low Temperature Condensing Unit
- 3 EA. 230 Volt, 1 Phase Electric Defrost with Evaporator
- 3 EA. SPO SBFSE-B-ZP 3/8" X 1/2" (expansion valve)

General Specifications

All replacement systems must use R404A gas, and must have a copeland serviceable compressor.

All evaporators must be equipped with solenoid valves and all condensing units are for outside use.

Emphasis to be focused on security, durability, dependability, and cost efficiency.

Bid Schedule

1. Medium Temperature Systems – Lump Sum \$ _____

2. Low Temperature Systems – Lump Sum \$ _____

Firm Name _____

Printed Name _____ Signature _____

Address _____

City _____ State _____ Zip Code _____

Phone # _____ Fax # _____

Email Address: _____

(Submit this Bid Form, a completed copy of the Event Details, and all other documents required by the Event Details.)